



City of Leander

REQUEST FOR PROPOSAL
COLD WATER RADIO FREQUENCY WATER METERS AND READING SYSTEM
ADDENDUM #2

RFP No. S13-012

Addendum #: 2

Date: April 21, 2014

Please note the clarification and/or additional information for the solicitation referenced above.

1. **Q: Will the City consider multi-jet meters for their 5/8, 1, 1 & ½ and 2 inch meters?**
 A: No. The City will only consider displacement type, magnetic drive for meters up to 2 inches.

Approved by

Joy Simonton, Purchasing Agent

By the signatures affixed below, Addendum No. 2 is hereby incorporated into and made a part of the above referenced solicitation.

ACKNOWLEDGED

Vendor

Authorized Signature

Date

RETURN ONE COPY SIGNED COPY OF THIS ADDENDUM TO THE PURCHASING OFFICE WITH YOUR SEALED PROPOSAL. FAILURE TO DO SO MAY AUTOMATICALLY DISQUALIFY YOUR RESPONSE FROM CONSIDERATION FOR AWARD.